



8560 Arlington Boulevard
Fairfax, Virginia 22031

APPROVED PRODUCTS LIST



December 2013

Fairfax Water

Approved Products List

Table of Contents

DIVISION 2 – SITEWORK.....	1
02300 Earthwork	1
02371 Geotextiles.....	1
02400 Tunneling, Boring, and Jacking	2
Casing Insulators (Spacers).....	2
Liner Plate	3
02500 Utility Services	4
02510 Water Distribution	4
Pipe Materials.....	4
Ductile Iron Pipe (DIP).....	4
Steel Pipe	5
Prestressed Concrete Cylinder Pipe (PCCP).....	6
High Density Polyethylene Pipe (HDPE).....	7
Fittings.....	8
Standard Pattern Mechanical Joint Fittings.....	8
Compact Mechanical Joint Fittings.....	9
Swivel Fittings.....	10
2-Inch Brass, Ductile and Galvanized Fittings & Pipe	11
Brass and Copper Service Fittings.....	13
High Density Polyethylene Fittings (HDPE)	14
Valves.....	15
Air Release Valves	15
Butterfly Valves.....	16
Butterfly Valve Operators	17
Gate Valves	18
Flow and Pressure Control Valves	19
Swing Check Valves.....	20
Vacuum Valves.....	21
Valve Boxes.....	22
Valve Stem Extensions.....	23
Hydrants.....	24
Meters	25
Cold Water Meters.....	25
Fire Line Meters.....	27
Wholesale Meters	28
Meter Boxes.....	29
Meter Box Covers.....	30
Pipe Joints.....	31
Flanged Joints - Pipe.....	31
Push-on Joints - Pipe	32
Restrained Joints - Pipe	33
Couplings	34
Couplings.....	34
Flanged Adapters	35
Tapping Materials.....	36
Tapping Valves	36
Tapping Saddles for Cast Iron and Ductile Iron Pipe	37
Tapping Sleeves for Cast Iron, Asbestos Concrete or Ductile Iron Pipe.....	38
Tapping Saddles for PCCP	39
Weld-On Saddles for Steel Pipe.....	40
Other	41
Backflow Preventer.....	41
Copper Tubing.....	42

Fairfax Water

Approved Products List

Table of Contents

Service Saddles.....	43
HDPE Tracer Wire.....	44
Restrained Joint Identification Tape.....	45
Tangent (Offset) Tee.....	46
Split Swivel Glands.....	47
02512 Thrust Restraints.....	49
Mechanical Joint Glands.....	49
Ductile Iron Restraining Glands & Gaskets.....	50
PVC Restraining Glands.....	52
DIVISION 3 – CONCRETE.....	53
03400 Precast Concrete.....	53
Precast Vaults.....	53
Vault Wall Seals.....	55
DIVISION 5 – METALS.....	56
05500 Metal Fabrications.....	56
Access Doors.....	56
Vault Ladder Safety Post.....	57
Vault Ladder.....	58
DIVISION 13 – SPECIAL CONSTRUCTION.....	59
13110 Cathodic Protection.....	59
Corrosion Rate Probes.....	59
Dielectric Coating – External Pipe Surfaces.....	60
Electric Tape.....	61
Insulating Devices.....	62
PVC Pipe Inserts.....	62
Insulated Flange.....	63
Insulated Union.....	64
Insulated Flange Kit (Isolation Inserts) – Internal Pipe Coating.....	65
Petrolatum Tape Coating.....	66
Polyethylene Tubing (Encasement).....	67
Polyurethane Coating.....	68
Reference Electrodes.....	69
Steel Hand Stamp.....	70
Survey Markers.....	71
Test Stations.....	72
Thermite Welding Equipment.....	73
Thermite Weld Coating Materials.....	74
Utility Warning Tape.....	75
Wire Connectors and Terminations.....	76
Terminal Lugs.....	76
Butt Splices.....	77
Magnesium Anodes.....	78

This page left intentionally blank.

Fairfax Water

Approved Products List

General Notes

1. Questions or comments regarding the Approved Product List should be directed to Fairfax Water's Manager of Engineering at (703) 289-6378.
2. Fairfax Water has established procedures for the review and approval of products used in the water system. All products considered for use in the water system must be reviewed and approved by the Product Review Committee prior to being included in the Approved Product List.
3. It is understood that all standards referenced in the Approved Product List shall be the latest version of that standard, regardless of the year or date indicated.
4. After an item is approved, the Manufacturer or representative must inform Fairfax Water, in writing, of any modifications in design or material. Changes in design or material may require further evaluation and approval of the product.
5. Fairfax Water may withdraw any approval as a result of design change, field observation, testing, product failure, or other factors which, in Fairfax Water's opinion, warrant such withdrawal.

Revised: 6/5/2008

This page left intentionally blank.

DIVISION 2 – SITEWORK

02300 Earthwork

02371 Geotextiles

Geotextiles

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM D751 Standard Test Methods for Coated Fabrics
- B. ASTM D1117 Standard Methods of Testing Non-woven Fabrics
- C. ASTM D1682 Standard Test Methods for Breaking Load and Elongation of Textile Fabrics
- D. Virginia Department of Transportation (VDOT) Road and Bridge Specifications

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall conform with Section 245 of VDOT Road and Bridge Specifications.
- B. Geotextile fabric shall be pervious and shall consist of either woven or non-woven sheets of polypropylene yarn.
- C. The geotextile fabric shall be free of defects or flaws that may significantly affect physical properties.
- D. All edges of woven geotextile fabric shall be salvaged.
- E. The fabric shall be treated to provide resistance to degradation from ultraviolet radiation for a minimum period of 180 days.
- F. Minimum Strength:

<u>Strength Test</u>	<u>Certified Minimum Average Roll Values</u>	
	<u>Type I</u>	<u>Type II</u>
Grab Strength (ASTM 1682)	270 lbs.	180 lbs.
Puncture Strength (ASTM 751)	110 lbs.	75 lbs.
Mullen Burst Strength (ASTM 751)	430 psi	290 psi
Trapezoid Tear Strength (ASTM 1117)	75 psi	50 psi
Permittivity	1.05 sec.-1	1.45 sec.-1

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Belton, Industries, Inc., Beltech 200 Polypropylene

END OF SECTION

02400 Tunneling, Boring, and Jacking

Casing Insulators (Spacers)

Casing Insulators (Spacers)

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Hot rolled, 14-gauge Carbon steel with polyvinyl chloride coating.
- B. 304 Stainless steel material.
- C. All hardware shall be electroplated steel.
- D. All stainless steel welds shall be chemically passive.
- E. Minimum 7-inch width for 12-inch diameter pipe or smaller.
- F. Minimum 11-inch width for 14-inch diameter or larger.
- G. Runners shall be made of reinforced, high strength polymer with high abrasion resistance and a low coefficient of friction.
- H. Minimum of three casing insulators required per pipe length, or more as required by the manufacturer, with a maximum separation of six feet.
- I. Minimum 2-inch width runners.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Cascade Waterworks Manufacturing Company (Stainless Steel)
- B. Pipeline Seal and Insulator, Inc. (Carbon Steel with polyvinyl chloride coating)
- C. Advanced Products & Systems, Inc. Model SI
- D. RACI (Polyethylene)
- E. PowerSeal Pipeline Products Corp./Model 4810
- F. BWM
- G. CCI Pipeline Systems (Stainless Steel)

END OF SECTION

Revised: 6/1/2011

Liner Plate

Liner Plate

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A123 Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products
- B. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60 000 PSI Tensile Strength
- C. ASTM A153 Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Hot-dipped galvanized steel, ASTM A123.
- B. Thickness shall be a minimum of 8 ga. in thickness and should be capable of supporting an AASHTO HS20 loading as well as all other superimposed loads.
- C. Each section shall be certified by the manufacturer for thickness and material quality, galvanizing quality, and quality of bituminous coating.
- D. Loading requirements for railway crossings in accordance with AREA Manual for Railway Engineering or the railroad company whose track is being crossed, whichever is stricter.
- E. One grout hole minimum for every three liner plate rings.
- F. Grout holes shall be 2-inch half couplings provided with 2-inch cast iron plugs.
- G. Bolts and nuts shall conform to ASTM A307, Grade B.
- H. Bolts and nuts shall be hot-dipped galvanized in accordance with ASTM A153.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Contech Construction Products (formerly Armco, Inc.)
- B. Republic Steel Corporation
- C. Commercial Pantex Sika, Inc.

END OF SECTION

02500 Utility Services

02510 Water Distribution

Pipe Materials

Ductile Iron Pipe (DIP)

Ductile Iron Pipe (DIP)

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C151/A21.51 Ductile-Iron Pipe, Centrifugally Cast, for Water
- B. ANSI/AWWA C104/A21.4 Cement Mortar Lining for Ductile-Iron Pipe and Fittings for Water

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Class 52.
- B. Mark manufacturer, weight, class, and thickness on outside of each pipe.
- C. Mark DI or DUCTILE.
- D. Cement Mortar Lining in accordance with ANSI/AWWA C104/A21.4 and thickness as follows:
 - 1/8-inch cement lining for 12 inch and smaller pipe diameter (double thickness)
 - 3/16-inch cement lining for 14 inch through 24 inch pipe diameter (double thickness)
 - 1/4-inch cement lining for 30 inch through 54 inch pipe diameter (double thickness)This shall include the bituminous seal coat.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. Atlantic States Cast Iron Pipe Company
- C. Clow Water Systems Company
- D. Griffin Pipe Products Company
- E. McWane, Inc.
- F. Pacific States Cast Iron Pipe Company
- G. U.S. Pipe and Foundry Company

END OF SECTION

Steel Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C200 Steel Water Pipe 6 inches and Larger
- B. ANSI/AWWA C203 Coal Tar Protective Coatings and Linings for Steel Water Pipelines – Enamel and Tape-Hot Applied
- C. ANSI/AWWA C205 Cement-Mortar Protective Lining and Coating for Steel Water Pipe 4-inch and Large Shop Applied
- D. ANSI/AWWA C206 Field Welding of Steel Water Pipe
- E. ANSI/AWWA C210 Liquid Epoxy Coating Systems for the Interior and Exterior of Steel Water Pipelines
- F. ANSI/AWWA C214 Tape Coating Systems for the Exterior of Steel Water Pipelines
- G. ANSI/AWWA M11 Steel Pipe: A Guide for Design and Installation
- H. ANSI/ASME B36.10 Welded and Seamless Wrought Steel Pipe

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Steel pipe may be either fabricated or mill type.
- B. The specified size of the fabricated pipe shall be the actual inside diameter of pipe, for pipe 14 inches and larger.
- C. The specified size of mill pipe shall be the nominal pipe size set forth in ANSI/ASME B36.10.
- D. Pipe wall thickness requirements vary with diameter and are provided in project specifications.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Northwest
- B. American Cast Iron Pipe Company
- C. Permalok (for use as steel casing pipe only)

END OF SECTION

Prestressed Concrete Cylinder Pipe (PCCP)

Prestressed Concrete Cylinder Pipe (PCCP)

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA 301 Prestressed Concrete Pressure Pipe, Steel Cylinder, for Water and Other Liquids
- B. ASTM Standard Specification for Portland Cement, Designation C 150, Type I

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. The working pressure shall be stenciled thereon, including any special stationing requirements.
- B. Cement used shall comply with ASTM standard for C150, Type I.
- C. Steel cylinder shall withstand design lateral forces and overburden.
- D. No welded joints allowed.
- E. Dead Load Allowance for Soil Weight – 120lb/cf
- F. Coefficient of Friction – 0.3
- G. All exterior surfaces shall receive shop-applied exterior coat of polyamide epoxy-cal tar, minimum dry film thickness of 20 mils. Manufacturer shall certify coating before shipping.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Hanson Pipe

END OF SECTION

HDPE Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C901 – Polyethylene Pressure Pipe and Tubing, ½ -inch through 3-inch for water service
- B. ANSI/AWWA C906 – Polyethylene Pressure Pipe and Fittings, 4-inch through 12-inch for water distribution
- C. National Science Foundation – Standard 61 Drinking Water System Components

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be NSF 61 approved for use in potable water systems.
- B. 2-inch through 8-inch diameter.
- C. Minimum working pressure of 160 psi, DR 11
- D. 4000 Series (DIPS)
- E. Pipe shall be heat fused with zero leakage joints.
- F. Standard 40 feet lengths shall be provided.
- G. A minimum of two-percent of carbon black content to protect against ultraviolet degradation.
- H. Pipe color scheme shall be: Black pipe with blue lettering or a blue line on the pipe.
- I. Writing color on exterior of pipe shall be blue.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Performance Pipe

END OF SECTION

Fittings

Standard Pattern Mechanical Joint Fittings

Standard Pattern Mechanical Joint Fittings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C104/A21.4 Cement Mortar Lining for Ductile-Iron Pipe and Fittings for Water
- B. ANSI/AWWA C110/A21 Ductile Iron and Gray Iron Fittings 3-inch through 48-inch for Water
- C. ANSI/AWWA C111/A21 Rubber Gasket Joints for Ductile Iron Pressure Pipe and Fittings
- D. ANSI/AWWA C116/A21 Protection Fusion Bonded Epoxy Coatings for the Interior and Exterior Surfaces of Ductile Iron and Gary-Iron Fittings for Water Supply Service
- E. ANSI/AWWA C550/A21 Standard for Protective Epoxy Interior Coatings for Valves and Hydrants
- F. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60 000 PSI Tensile Strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Cast gray iron, minimum rated 250 psi.
- B. Ductile iron, minimum rated 350 psi 24-inch diameter or smaller.
- C. Ductile-Iron minimum rated 250 psi 30-inch diameter or larger.
- D. Cement Lining (ANSI/AWWA C104/A21.4)
 - 1/16-inch – 1-inch through 12-inch
 - 3/32-inch – 14-inch through 24-inch
 - 1/8 inch – 30-inch through 54-inchThis shall include the bituminous seal coat. Fusion bonded epoxy with 6-8 mils thickness is also acceptable. Sleeves, plugs and caps shall not be cement lined.
- E. Mechanical joint bolt holes shall straddle the centerline of fittings.
- F. Bolts and nuts shall be low-alloy steel in accordance with ANSI/AWWA C111/A21.11.
- G. Plugs shall be flat faced, push-on or mechanical joint.
- H. Sleeves shall be long pattern.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. Clow Water Systems Company
- C. Tyler / Union
- D. U.S. Pipe and Foundry Company
- E. Sigma Corporation
- F. Star Pipe Products
- G. SIP Industries

END OF SECTION

Revised: 12/2/2013

Compact Mechanical Joint Fittings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA 104/A21.4 Cement Mortar Lining for Ductile Iron Pipe and Fittings for Water Service
- B. ANSI/AWWA C153/A21.53 Ductile-Iron Compact Fittings, 3 in. through 24 in. (76 mm Through 610 mm) and 54 in. through 64 in. (1,400 mm Through 1,600 mm), for Water Service
- C. ASTM A307 Standard Specification Carbon Steel Bolts and Studs, 60,000 psi tensile strength,

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Class 350
- B. Cement lining in accordance with ANSI/AWWA C104/A21.4
 - 1/16-inch – 1-inch through 12-inch
 - 3/32-inch – 14-inch through 24-inch
 - 1/8 inch – 30-inch through 54-inchThis shall include the bituminous seal coat. Fusion bonded epoxy with 6-8 mils thickness is also acceptable. Sleeves, plugs and caps shall not be cement lined.
- C. Mechanical joint bolt holes shall straddle the centerline of fittings.
- D. Bolts and nuts shall be low-alloy steel in accordance with ANSI/AWWA C111/A21.11.
- E. Fitting design shall prevent T-head bolts from rotating.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Sigma Corporation
- B. Tyler / Union
- C. U.S. Pipe and Foundry Company
- D. Star Pipe Products
- E. American Cast Iron Pipe Company
- F. SIP Industries

END OF SECTION

Swivel Fittings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C104/A21 Cement Mortar Lining for Ductile Iron Pipe and Fittings for Water Service
- B. ANSI/AWWA C110/A21.10 Ductile-Iron and Gray-Iron Fittings, 3 in through 48 in (75mm through 1200mm) for Water and Other Liquids
- C. ANSI/AWWA C153/A21.53 Ductile-Iron Compact Fittings, 3 in. through 24 in. (76 mm Through 610 mm) and 54 in. through 64 in. (1,400 mm Through 1,600 mm), for Water Service
- D. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Cement lining (ANSI/AWWA C104/A21.4)
 - 1/16-inch – 1-inch through 12-inch
 - 3/32-inch – 14-inch through 24-inchThis shall include the bituminous seal coat. Fusion bonded epoxy with 6-8 mils thickness of is also acceptable.
- B. Mechanical joint bolt holes shall straddle the centerline of fittings.
- C. Bolts and nuts shall be low-alloy steel in accordance with ANSI/AWWA C111/A21.11.
- D. Fitting design shall prevent T-head bolts from rotating.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Tyler / Union
- B. U.S. Pipe and Foundry Company
- C. NAPP/CO/Sigma Corporation
- D. Star Pipe Products
- E. SIP Industries

END OF SECTION

2-Inch Brass, Ductile and Galvanized Fittings & Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ASTM B687 Standard Specification for Brass, Copper, and Chromium-Plated Pipe Nipples
- B. ASTM B62 Standard Specification for Composition Bronze or Ounce Metal Castings
- C. ASTM A153 Hot-Dipped Galvanized
- D. ANSI B16.3 Malleable and Ductile Iron Threaded Fittings
- E. ASTM B43 Standard Specification for Seamless Red Brass Pipe, Standard Sizes
- F. ASTM A53 Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless
- G. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements consisting of, but not limited to material type, dimensions, and conditions.

- A. Pipe sizes 2-inch for blow-offs and air release valves
- B. Malleable Iron Threaded Fittings, Class 150 and 300.
- C. Steel Welded Nipples Schedule 40 and Schedule 80.
- D. Bronze threaded Fittings Class 125.
- E. Seamless Red Brass Nipples Schedule 40.
- F. An independent laboratory certification must be provided giving evidence that the brass goods comply with the material standards listed above.
- G. Product must be marked with a lead-free identifier (such as “NL” or LF”) and with the verifying agency’s mark.
- H. Malleable Iron Fittings and steel welded nipples are exempt from certification and marking requirements.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Merit Brass
- B. Harco (Ductile Iron Products only)

END OF SECTION

Brass and Copper Service Fittings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. AWWA C800 Underground Service Line Valves and Fittings
- B. ASTM F1807 Standard Specification for Metal Insert Fittings Utilizing a Copper Crimp Ring for SDR-9 Cross-linked Polyethylene Tubing
- C. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. An independent laboratory certification must be provided giving evidence that the brass goods comply with the material standards listed above.
- B. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Ford Meter Box Company, Inc.
- B. Mueller Company (Specify "N" after part number when ordering)
- C. Cambridge-Brass
- D. A.Y. McDonald Manufacturing Company

END OF SECTION

High Density Polyethylene Fittings (HDPE)

HDPE Fittings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C906 – Polyethylene Pressure Pipe and Fittings, 4-inch through 12-inch for water distribution
- B. National Science Foundation – Standard 61 Drinking Water System Components

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be NSF 61 approved for use in potable water systems.
- B. 2-inch through 8-inch diameter.
- C. Minimum working pressure of 160 psi, DR 11
- D. 4000 Series (DIPS)
- E. Fittings shall be heat fused or electrofused (couplings only) with zero leakage joints.
- F. A minimum of two-percent of carbon black content to protect against ultraviolet degradation.
- G. Fitting color shall be black

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Performance Pipe
- B. Central Plastics Company

END OF SECTION

Valves

Air Release Valves

Air Release Valves (Automatic)

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C512 Air Release Air/Vacuum, and Combination Air Valves for Waterworks Service
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 1-inch inlet connection.
- B. Rated 300 psi working pressure.
- C. Floats and ball shall be stainless steel.
- D. All working parts shall be constructed of brass, stainless steel, or other non-corrosive material.
- E. Components constructed of brass and bronze in contact with potable water shall be certified as being compliant with NSF 372.
- F. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. GA Industries (Except Models 284 and 991 DC)
- B. Valmatic

END OF SECTION

Butterfly Valves

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C504 Rubber Seated Butterfly Valves
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Minimum size 16-inch.
- B. Short body type Class 150B conforming to ANSI/AWWA C504.
- C. Seats shall be rubber, permanently bonded and/or mechanically retained to the valve body.
- D. Mechanical joint and valves Class 150B conforming to ANSI/AWWA C504.
- E. All fasteners exposed on the valve's exterior to be T-304 stainless steel (ie. bolts that fasten bonnets, packings of stems and operator gear boxes).
- F. Components constructed of brass and bronze in contact with potable water shall be certified as being compliant with NSF 372.
- G. Product must be marked with a lead-free identifier (such as "NL" or "LF") and with the verifying agency's mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Henry Pratt Company - Groundhog
- B. Mueller Company – Lineseal III (Specify "N" after part number when ordering)
- C. Dezurick – BAW Model 150B

END OF SECTION

Butterfly Valve Operators

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C504 Rubber Seated Butterfly Valves
- B. ASTM 304 Standard Specification Stainless Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. All operators must be capable of operating Class 150B valves.
- B. All operators shall be capable of developing the maximum torque listed in Table 4 of ANSI/AWWA C504 for Class 150B valves.
- C. Bolts and nuts shall be stainless steel, ASTM 304.
- D. Counter-clockwise rotation of operating nuts to open.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Mueller Company (Specify "N" after part number when ordering)
- B. Philadelphia Gear Corporation (Limitorque - electrical operators only)
- C. Henry Pratt Company

END OF SECTION

Gate Valves

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. 12" and smaller shall meet ANSI/AWWA C509 Resilient-Seated Gate Valves for Water Supply Service
- B. ASTM T-304 Stainless Steel Bolts and Studs, 60,000 psi tensile strength
- C. 14" shall meet ANSI/AWWA C515 Reduced Wall, Resilient-Seated Gate Valves for Water Supply Service

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. All requirements apply to Double-Disc and Resilient-Seated Gate Valves.
- B. Maximum size - 14-inch.
- C. 2-inch and smaller shall be furnished with threaded ends.
- D. 3-inch and larger shall have mechanical joint ends.
- E. Provide O-ring seals.
- F. Counter-clockwise rotation of operating nut to open.
- G. Non-rising stem.
- H. Bolts and nuts shall be ASTM T-304 Stainless Steel.
- I. Gate valve body to be ductile iron with bronze or stainless steel stem

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Clow Valve Company (Resilient Wedge) - Model 2639-F6100 w/NDZ, specify heavy stem (2"-12" only)
- B. Kennedy Valve Company - Model 8571DBYSS
- C. M&H Valve Company - Model 4067-DINDZ
- D. Mueller Company (Resilient-Seated only) - Model A2362-9000
- E. U.S. Pipe and Foundry Company (Resilient-Seated only) - A USP2-9000.
- F. American AVK - Standard Series 45
- G. J&S Valve – Series 6900 (Stainless Steel Stem)

END OF SECTION

Flow and Pressure Control Valves

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ASTM A536 Standard Specification for Ductile Iron Castings
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall provide tight shut off under conditions of no flow and shall not "hunt" under ordinary flow.
- B. Furnish each valve with all catalog-listed "optional" features, including, but not be limited to: flow clean strainer.
- C. Three shut-off cocks are required.
- D. Valve position indicator is required.
- E. Components constructed of brass and bronze in contact with potable water shall be certified as being compliant with NSF 372.
- F. Product must be marked with a lead-free identifier (such as "NL" or "LF") and with the verifying agency's mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Cla-Val Company (Excluding type 94-01)

END OF SECTION

Swing Check Valves

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. AWWA C508 Swing-Check Valves for Waterworks Service, 2 in (50 mm) through 24 in (600 mm)
- B. ASTM A536 Standard Specifications for Ductile Iron Castings
- C. National Science Foundation 61 Drinking Water System Components
- D. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 175 psi working pressure.
- B. Body and cover shall be made of ductile iron in accordance with ASTM 536.
- C. If rubber faced disk, the disk shall be of high quality elastomer.
- D. Shall be NSF 61 approved for use in potable water systems.
- E. Components constructed of brass and bronze in contact with potable water shall be certified as being compliant with NSF 372.
- F. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Cla-Val Company Model 584 Flex Check Valve
- B. Kennedy Valve Company , Figure 106A (rubber-faced disc)
- C. Mueller Company Series A2600 (rubber-faced disc) (Specify “N” after part number when ordering)
- D. Valmatic Series 500 (rubber-faced disc)
- E. APCO Valve & Primer Corporation – Series 100 (rubber-faced disc)

END OF SECTION

Revised: 3/14/2014

Vacuum Valves

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ASTM A126 Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings
- B. ASTM A216 Standard Specification for Steel Castings, Carbon, Suitable for Fusion Welding, for High- Temperature Service
- C. ASTM A536 Standard Specification for Ductile Iron Castings
- D. NSF 61 (BUNA rubber)
- E. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. The valve body, cover, and baffle shall be of ASTM A126 cast iron and ASTM 536 ductile iron, as applicable.
- B. The float, guide, shafts, and bushings shall be of Type 304 Stainless Steel.
- C. Seats shall provide a tight shutoff and be of Buna-N material compliant with NSF 61.
- D. An independent laboratory certification must be provided giving evidence that the goods comply with the material standards listed above.
- E. Components constructed of brass and bronze in contact with potable water shall be certified as being compliant with NSF 372.
- F. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Valmatic

END OF SECTION

Valve Boxes

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A48 Standard Specification for Gray Iron Castings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Cast Iron material shall be in accordance with ASTM A48, Class 25 minimum.
- B. All boxes shall have an outside ledge under the top ring.
- C. Top outside slip pipe shall not have flange at bottom.
- D. Valve boxes shall comply with Fairfax Water standard details.
- E. The manufacturer identification and country of origin, if other than U.S., shall be cast into all parts
- F. Minimum weights shall be as follows:
 - Cover 12.5 lbs.
 - Upper Section 37.5 lbs.
 - Lower Section 47.0 lbs.
 - Extension Section 17.0 lbs.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Bingham & Taylor, Fig. 4908
- B. R.B. Argawalla (India)/Capital Foundry
- C. Fastener Technologies (India)
- D. Crestwell Trading Company, Model A-1 (India)
- E. East Jordan Iron Works, Inc. (Only product numbers 85557126U, 85556036U & 85556518U)

END OF SECTION

Valve Stem Extensions

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A53 Standard Specification for steel pipe
- B. ASTM A36-05 Standard Specification for carbon structural steel

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Operating Nut shall be 2-inch square
- B. All extensions shall have a 4-inch X 1/4-inch welded steel centering ring
- C. Solid Steel Bar shall be 1-inch diameter minimum.
- D. Welded Square Tube shall be 2 ½-inches

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. BH Runyon Company
- B. Sigma Corporation
- C. Water Key

END OF SECTION

Hydrants

Fire Hydrants

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C502 Hydrants, Dry-Barrel Fire

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Fire hydrants shall be of 3-way class with a 5 1/4-inch main valve opening, with one 4-1/2-inch pumper outlet and two 2-1/2-inch hose outlets all with National Standard fire hose coupling threads.
- B. The hydrant shoe shall have at least one all bronze drain outlet.
- C. The hydrant shoe and barrel may be made of different material.
- D. The complete interior of the shoe shall have epoxy coating if the o-ring is in contact with cast iron.
- E. If the bottom o-ring is in contact with brass, no epoxy coating of the interior of the shoe is required.
- F. Hydrants shall be furnished with a breakaway feature that will break cleanly on the underside of flange upon impact. This shall consist of a break flange with a breakable stem coupling. Breakable bolts will not be accepted. This break flange shall also permit 360° rotation of the upper barrel to position nozzles in any desired position.
- G. Repair of hydrants shall be with Original Equipment Manufacturer's (O.E.M.) parts.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Kennedy Valve Company K81D 5 1/4-inch (UL/FM)
- B. Mueller Company Centurion 250A-423-5 1/4-inch (UL/FM)

END OF SECTION

Meters

Cold Water Meters

Cold Water Meters

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C700 Cold-Water Meters - Displacement Type, Bronze Main Case
- B. ANSI/AWWA C702 Cold Water Meters - Compound Type
- C. ANSI/AWWA C707 Water Meters, Encoder-Type, Remote-Registration Systems for Cold Water Meters
- D. ANSI/AWWA C701-07 Cold Water Meters – Turbine Type
- E. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Domestic/Commercial Sizes 5/8-inch through 2-inch.
- B. Compound Sizes 3-inch through 8-inch.
- C. Remote Registration.
- D. Components constructed of brass or bronze in contact with potable water shall be certified as being compliant with NSF 372.
- E. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

Sizes 5/8-inch through 2-inch

- A. Badger Meter, Inc.
- B. Sensus, OMNI Series
- C. Hersey Meter
- D. Neptune Technology Group
- E. Master Meter

Sizes 3-inch through 8-inch

- A. Sensus, OMNI Series C2, T2
- B. Neptune Technology Group

END OF SECTION

Fire Line Meters

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C703 Cold Water Meters – Fire Service Types
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Size 6-inch, 8-inch and 10-inch.
- B. Components constructed of brass or bronze in contact with potable water shall be certified as being compliant with NSF 372.
- C. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Sensus, OMNI Series
- B. Neptune Technology Group

END OF SECTION

Wholesale Meters

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. AWWA C701 Standard for Cold Water Meters – Turbine Type
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall conform to AWWA C701.
- B. The assemblies shall consist of valves, meters, strainers, and by-pass piping.
- C. Strainer shall be made of stainless steel, and the strainer housing shall be of ductile iron.
- D. Components constructed of brass or bronze in contact with potable water shall be certified as being compliant with NSF 372.
- E. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Sensus, OMNI Series T2
- B. Neptune Technology Group
- C. Badger Meter, Inc.

END OF SECTION

Meter Boxes

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C800 Underground Service Line Valves and Fittings (Also Included: Collected Standards for Service Line Materials)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be made of PVC only. No molded plastic.
- B. 18-inch inside diameter x 24-inch L.
- C. 27-inch inside diameter x 30-inch L.
- D. Non-tapered.
- E. Cut-outs are not permitted.
- F. Minimum Wall Thickness of 1/2-inch.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Bingham & Taylor
- B. Hunt Industries/Mueller Company

END OF SECTION

Meter Box Covers

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A48 Standard Specification for Gray Iron Castings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Class 25 minimum.
- B. Meter Box Cover shall comply with Fairfax Water standard detail.
- C. Foreign castings are allowed, subject to testing and approval.
- D. Country of origin must be cast into production.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. R.B. Argawalla/Capital Foundry
- B. Crestwell Trading Company
- C. Bingham & Taylor
- D. Fastener Technologies
- E. Uma Foundry

END OF SECTION

Pipe Joints

Flanged Joints - Pipe

Flanged Joints - Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C110/A21.10 Ductile-Iron and Gray-Iron Fittings, 3 in through 48 in (75mm through 1200mm) for Water and Other Liquids
- B. ANSI/AWWA C115/A21.15 Water Treatment – Flanged Ductile-Iron Pipe With Ductile-Iron or Gray-Iron Flanges
- C. ASTM A 307 Standard Specification for Carbon Steel Bolts and studs, 60,000 psi tensile strength
- D. ANSI/AWWA C111/A21.11 American National Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Drilled to ANSI Class 125 standard template in accordance with ANSI B16.1
- B. Gaskets - 12-inch diameter and smaller shall be full faced 1/16-inch thick.
- C. Gaskets shall extend to inside of bolt holes and shall be rubber with cloth inserts.
- D. Drop-in type gaskets may be used upon approval.
- E. Gasket by Crane Packing Company, Garlock Packing Company, and U.S. Rubber Company.
- F. Bolts and nuts shall be low-carbon steel in accordance ASTM A307, Grade B.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. U.S. Pipe and Foundry Co.
- C. Fast Fabricators

END OF SECTION

Push-on Joints - Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C115/A21 Flanged Ductile-Iron Pipe with Ductile-Iron or Gray-Iron Threaded Flange
- B. ANSI/AWWA C150 Thickness Design of Ductile-Iron Pipe
- C. ANSI/AWWA C151 Ductile-Iron Pipe, Centrifugally Cast for Water or Other Liquids
- D. ANSI/AWWA C111/A21.11 American National Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Rubber face gasket shall be bell and spigot type single elongated grooved basket.
- B. FKM/Viton gaskets required when excavated soils contain a Total Petroleum Hydrocarbon (TPH) concentration level of 10 mg/kg, or to the extent directed by Fairfax Water. Areas where FKM/Viton gaskets are installed shall require identification tape to be installed during backfill operations and laid one foot above the water main piping. Tape shall be marked "Caution, FKM/Viton Gaskets Below" or similar language approved by Fairfax Water.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s) and style(s) accepted:

- A. American Cast Iron Pipe Company - Fastite
- B. Griffin Pipe Products Company- Fastite, 30-inch to 48-inch
- C. U.S. Pipe and Foundry Company - Tyton Joint
- D. Atlantic States Cast Iron Pipe Company. -Tyton Joint
- E. Pacific States Cast Iron Pipe Company - Tyton Joint
- F. Clow Water Systems Company - Tyton Joint.
- G. McWane, Inc. – Tyton Joint
- H. FKM/Viton Gaskets:
 - 1. Champion Sales & Manufacturing, Inc.
 - 2. Specification Rubber Products, Inc.
 - 3. Atlantic Gasket Corporation

END OF SECTION

Restrained Joints - Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSW/AWWA C111/A21.11 Rubber Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- B. ASTM A307 Standard Specification for Carbon Steel Bolts and studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Field welding of restraining components is not permitted, unless authorized by Engineer.
- B. No Flexible adapters.
- C. Add bolt for sizes 4-inch to 16-inch.
- D. FKM/Viton gaskets required when excavated soils contain a Total Petroleum Hydrocarbon (TPH) concentration level of 10 mg/kg, or to the extent directed by Fairfax Water. Areas where FKM/Viton gaskets are installed shall require identification tape to be installed during backfill operations and laid one foot above the water main piping. Tape shall be marked "Caution, FKM/Viton Gaskets Below" or similar language approved by Fairfax Water.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s) and Joint Accepted

- A. American Ductile Iron Pipe Company - Lok-Ring Joint, Flex Ring (4" - 48")
- B. Griffin Pipe Products Company - Snap-Lok and Bolt-Lok, for 6-inch to 48-inch
- C. U.S. Pipe and Foundry Company - TR Flex, HP Lok (30" - 64")
- D. McWane, Inc. - TRFlex
- E. FKM/Viton Gaskets:
 - 1. Champion Sales & Manufacturing, Inc.
 - 2. Specification Rubber Products, Inc.
 - 3. Atlantic Gasket Corporation

END OF SECTION

Couplings

Couplings

Couplings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C111/A21 Rubber Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- B. ASTM 304 Standard Specification for Stainless Steel Bolts and studs, 60,000 psi tensile strength
- C. ASTM A536 Standard Specification for Ductile Iron Castings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 24-inch diameter or smaller.
- B. The body of the couplings shall be ductile iron or steel.
- C. Unless otherwise specified, MJ solid sleeves shall be used to join pipe of the same outside diameter.
- D. Bolts and nuts shall be stainless steel in accordance with ASTM 304.
- E. Gaskets shall be oil resistant synthetic rubber.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Ford Meter Box Company, Inc. Model FC1, FC2 and FC2W
- B. JCM Industries, Model 210, 212 and 301
- C. Romac Industries, Inc., Style 501 and Style FCA 501
- D. Smith-Blair, Inc. (Rockwell), Type 431, 441, 433, 435, 913, Quantum 461, 421 Top Bolt
- E. Dresser, Inc., Style 38, 53, 3153, Hymax 2000
- F. PowerSeal Pipeline Products Corp, Model 3500

END OF SECTION

Flanged Adapters

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C11/A21 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and fittings
- B. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi tensile strength
- C. ASTM A536 Standard Specification for Ductile Iron Castings
- D. National Science Foundation 61 Drinking Water System Components

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Sizes 3-inch to 12-inch and shall conform with AWWA C111.
- B. Ductile Iron shall be in accordance with ASTM A536.
- C. All bolt circles, sizes and spacing shall conform to ANSI 150lb flange drilling.
- D. Gasket shall be made of nitrile and be resistant to water and chemicals.
- E. O-rings shall be made of nitrile.
- F. Each item shall be shipped complete with bolts, nuts, and gaskets.
- G. Shall be NSF 61 approved for use in potable water systems.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Smith-Blair, Inc. 911, 912 and 913
- B. Star – Series 3200

END OF SECTION

Tapping Materials

Tapping Valves

Tapping Valves for Cast Iron, Asbestos Concrete, Prestressed Concrete Cylinder or Ductile Iron Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. AWWA C509 Resilient Seated Gate Valves for Water Supply Services
- B. ANSI/AWWA C111/A21 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and fittings
- C. ASTM D429 Standard Specification for Rubber Metal Bond
- D. AWWA C550 Protective Interior Coatings for Valves and Hydrants

System Description

Design and Performance Requirements

Section includes: technical requirements consisting of, but not limited to material type, dimensions, and conditions.

- A. Pipe sizes 4-inch to 12-inch.
- B. Gate valve body to be ductile iron with bronze stem.
- C. ANSI B16.1 Class 125 flanged end with centering ring.
- D. Bolts and Nuts shall be stainless steel in accordance with ASTM 304.
- E. Rubber seal gaskets shall have a 250psi pressure rating.
- F. Shall be NSF 61 approved for use in potable water systems.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Kennedy, C-509 Resilient Wedge, Model 8950DBYSS
- B. Clow, C-509 Resilient Wedge, Model 2639-F6114 w/ NDZ
- C. Mueller Company, T2362-9000 Resilient Wedge
- D. US Pipe and Foundry Company, T2362-9000 Resilient Wedge
- E. M&H, C-509 Resilient Wedge, Model 4751-DINDZ

END OF SECTION

Revised: 7/26/2010

Tapping Saddles for Cast Iron and Ductile Iron Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C111/A21 Rubber-gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- B. ANSI/AWWA C151/A21 Ductile-Iron Pipe, Centrifugally Cast for Water or Other Liquids
- C. ASTM 304 Standard Specification for Stainless Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Minimum pipe size 16-inch diameter.
- B. Ductile Iron body in conformance with AWWA C151.
- C. Shall have stainless steel straps and nuts with anti-seize threads.
- D. Rubber seal gaskets shall have a 250psi pressure rating.
- E. Shall provide O-ring SBR sealing gasket conforming to AWWA C111.
- F. Maximum tapping size approved for various pipe sizes: 16-inch x 8-inch, 20-inch x 10-inch, 18-inch x 8-inch, 24-inch x 12-inch. Larger sizes may be considered on a case by case basis.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. U.S. Pipe and Foundry Company

END OF SECTION

Tapping Sleeves for Cast Iron, Asbestos Concrete or Ductile Iron Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM 304 Standard Specification for Stainless Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Cast iron or ductile iron material, or steel (MJ x MJ x Flange and epoxy coating required)
- B. End gasket on all sizes.
- C. Tap sizes up to one pipe size smaller than pipe being tapped for CIP and ACP.
- D. Tap sizes up to same pipe size being tapped for DIP (size on size).
- E. Mechanical joint.
- F. Bolts and nuts shall be stainless steel, ASTM 304 Standard Specification stainless steel bolts and studs, 60,000 psi tensile strength, Grade B.
- G. Minimum rated water pressure of 150 psi and test to 300psi.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. American Flow Control
- C. Clow Water Systems Company
- D. Mueller Company
- E. Tyler / Union
- F. U.S. Pipe and Foundry Company
- G. Waterous
- H. Smith-Blair, Inc. No. 624
- I. JCM Industries

END OF SECTION

Tapping Saddles for PCCP

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A536 Standard Specification for Ductile Iron Casting
- B. ASTM 304 Standard Specification for Stainless Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 16-inch x 6-inch and 8-inch
- B. 20-inch x 6-inch, 8-inch and 12-inch
- C. 24-inch x 6-inch, 8-inch and 12-inch
- D. 30-inch x 6-inch, 8-inch and 12-inch
- E. 36-inch x 6-inch, 8-inch, 12-inch, and 16-inch
- F. 42-inch x 6-inch, 8-inch, 12-inch, 16-inch and 20-inch
- G. 48-inch x 6-inch, 8-inch, 12-inch, 16-inch, 20-inch, and 24-inch
- H. Strap type tap only for connections 3/4-inch through 2-1/2-inch (wire or strapless not allowed)
- I. Bolts and Nuts shall be stainless steel in accordance with ASTM 304.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Hanson Pipe Company - Drawing No. 3211-B
- B. JCM Industries No. 415
- C. Romac Industries, Inc. No. FTS435
- D. Smith-Blair, Inc. No. 362 (tapping saddle for services)
- E. Smith-Blair, Inc. No. 625

END OF SECTION

Weld-On Saddles for Steel Pipe

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A536 Standard Specifications for Ductile Iron Castings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall comply with ASTM A536.
- B. Gaskets shall be of Buna- N

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. JCM Industries
- B. Smith-Blair, Inc.

END OF SECTION

Other

Backflow Preventer

Backflow Preventer

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C510 Double Check Valve Backflow-Prevention Assembly
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall conform with AWWA C511.
- B. Dual check valve assembly with reduced pressure zone between the check valves.
- C. Bronze body with threaded end connections.
- D. Components constructed of brass or bronze in contact with potable water shall be certified as being compliant with NSF 372.
- E. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Zurn Wilkins

END OF SECTION

Copper Tubing

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM B88 Standard Specification for Seamless Copper Water Tube

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Type "K" soft copper.
- B. Product shall conform to ASTM B88.
- C. Packaging - pancake coils through 1-1/2-inch, regular coil through 2-inch.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Cambridge -Lee
- B. Cerro
- C. Halstead
- D. Howell
- E. Mueller Company
- F. Reading
- G. Wieland

END OF SECTION

Service Saddles

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. National Science Foundation 61 Drinking Water System Components
- B. ASTM A536 Standard Specifications for Ductile Iron Castings
- C. ASTM A283 Standard Specification for Low and Intermediate Tensile Strength Carbon Steel Plates

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Body and tapped inserts shall be of ASTM A536 Ductile Iron.
- B. Straps, washers and nuts shall be of 18-8 Type 304 Stainless Steel.
- C. Gaskets shall be made of a rubber compound resistant to water, oil, and other chemicals.
- D. Shall withstand a working pressure of 300 psi for pipes 24-inch and smaller, and 250 psi for pipes greater than 24-inch.
- E. Shall be fusion-bonded epoxy coated for corrosion resistance.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. JCM Industries 406, 418
- B. Smith-Blair, Inc. 317
- C. Mueller Company DR1S, DR2S
- D. Ford Meter Box Company, Inc. FC101, FC202
- E. Romac Industries, Inc. R101N, R202NS

END OF SECTION

HDPE Tracer Wire

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 6-ga. single conductor coated copper wire installed approximately 3 inches (75mm) above water main.
- B. Where HDPE pipe is placed by the directional drill method, the tracer wire shall be taped to the pipe every 5 feet (1500mm) before installation.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. NONE

END OF SECTION

Restrained Joint Identification Tape

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Tape shall be marked "Caution Restrained Joint Below".
- B. All restrained joint piping shall be identified in the field with identification tape to be installed during backfill operations and placed one-foot above water main piping.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Northtown Company
- B. Pro-Line Safety Products Company

END OF SECTION

Tangent (Offset) Tee

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C110/A21.10 Ductile-Iron and Gray-Iron Fittings, 3 in through 48 in (75 mm through 1200 mm), for Water and Other Liquids
- B. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. See Technical Requirements for Standard Pattern Fittings.
- B. Bolts and nuts shall be low-carbon steel, ASTM A307, Standard Specification carbon steel bolts and studs, 60,000 psi tensile strength, Grade B.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Backman Foundry

END OF SECTION

Split Swivel Glands

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Product shall be made of ductile iron.
- B. Bolts and nuts shall be low-carbon steel ASTM A307, Grade B.
- C. Side flanged and overlapping ears are permitted by appropriate manufacturers listed below.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Eagle Foundry/Central Castings Company - bolt
- B. U.S. Pipe and Foundry Company - bolt
- C. Sigma Corporation - bolt
- D. Tyler/Union - bolt and overlapping ears

END OF SECTION

Utility Crossings

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

System Description

Product shall adhere to the latest version of:

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Separation of 6 inches or less for crossing of non- metallic pipe requires expansion material.
- B. Separation of 12 inches or less for crossing of metallic pipe requires separator mesh.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s) – Expansion Material:

- A. A.W.R. Grace and Co. – Rodofoam No. 327, Vinylfoam No. 327
- B. Sonneborn-Lotech – Vinylfoam No. 327

Approved Manufacturer(s) – Separator Mesh:

- A. Stuart Steel Protection Corp. – Stuart Rockstop

END OF SECTION

02512 Thrust Restraints
Mechanical Joint Glands

Mechanical Joint Glands

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C111/A21.11 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- B. ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi tensile strength

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Ductile Iron - all sizes.
- B. Bolts and nuts shall be low-carbon steel, ASTM A307, Standard Specification carbon steel bolts and studs, 60,000 psi tensile strength, Grade B.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Cast Iron Pipe Company
- B. Griffin Pipe Products Company
- C. Tyler/Union
- D. Eagle Foundry/Central Castings Company
- E. U.S. Pipe and Foundry Company
- F. Sigma Corporation/Russell Pipe
- G. Jinan Kinger Industrial Corporation/Proselect
- H. Star Pipe Products

END OF SECTION

Ductile Iron Restraining Glands & Gaskets

Ductile Iron Restraining Glands & Gaskets

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A536 Standard Specification for Ductile-Iron Castings
- B. ANSI/AWWA C111/A21.11 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- C. ANSI/AWWA C153/A21.53 Ductile-Iron Compact Fittings 3 in through 24 in (76 mm through 610mm) and 54 in through 64 in (1,400 mm through 1,600 mm), for Water Service

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Glands shall be made of ductile iron conforming to ASTM A536.
- B. Restraining devices shall be manufactured of ductile iron, heat treated to a minimum hardness of 370 BHN.
- C. Dimensions of the gland shall be such that it can be used with the standardized mechanical joint bell and tee-head bolts conforming to AWWA C111 and AWWA C153.
- D. Twist off bolts shall be used to ensure proper actuating of the restraining devices.
- E. 3-inch - 16-inch: pressure rating of 350 psi
18-inch - 48-inch: pressure rating of 250 psi.
- F. Foster bolt through restrained joints – “Foster Adapter”.
- G. FKM/Viton gaskets required when excavated soils contain a Total Petroleum Hydrocarbon (TPH) concentration level of 10 mg/kg, or to the extent directed by Fairfax Water. Areas where FKM/Viton gaskets are installed shall require identification tape to be installed during backfill operations and laid one foot above the water main piping. Tape shall be marked “Caution, FKM/Viton Gaskets Below” or similar language approved by Fairfax Water.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. EBBA Iron Sales, Inc.,- Megalug Series 1100 (EBBA Seal Gasket as manufactured by EBBA Iron, Inc. required with this gland)
- B. Sigma Corporation - One-Lok (Ductile Iron pipe only)
- C. Ford Meter Box Company, Inc. - 1400 Uniflange
- D. U.S. Pipe and Foundry Company - Field Lok 350 Gaskets (16" and under)
- E. Star Pipe Products - Stargrip Series 3000
- F. Tyler/Union - TUFGRIP TLD for DIP
- G. Smith-Blair, Inc. - Cam Lock Model 111 (DIP)
- H. Infact Corporation - Foster Adapters
- I. American Ductile Iron Pipe Company - Fast Grip Gasket (16" and under)
- J. McWane, Inc. - Sure Stop 350 Gaskets (16" and under)
- K. Griffin Pipe Products Company - Talon Gasket (4" through 16")
- L. FKM/Viton Gaskets:
 - 1. Champion Sales & Manufacturing, Inc.
 - 2. Specification Rubber Products, Inc.
 - 3. Atlantic Gasket Corporation

END OF SECTION

PVC Restraining Glands

PVC Restraining Glands

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM A536 Standard Specification for Ductile-Iron Castings
- B. ANSI/AWWA C111/A21.11 Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings
- C. ANSI/AWWA C153/A21.53 Ductile-Iron Compact Fittings 3 in through 24 in (76 mm through 610mm) and 54 in through 64 in (1,400 mm through 1,600 mm), for Water Service

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Glands shall be made of ductile iron conforming to ASTM A536.
- B. Restraining devices shall be manufactured of ductile iron, heat treated to a minimum hardness of 370 BHN.
- C. Dimensions of the gland shall be such that it can be used with the standardized mechanical joint bell and tee-head bolts conforming to AWWA C111 and AWWA C153.
- D. Twist off bolts shall be used to ensure proper actuating of the restraining devices.
- E. 3-inch - 16-inch: pressure rating of 350 psi
18-inch - 48-inch: pressure rating of 250 psi.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. EBBA Iron Sales, Inc., - Series 2000PV (EBBA Seal Gasket as manufactured by EBBA Iron, Inc. required with this gland)

END OF SECTION

DIVISION 3 – CONCRETE

03400 Precast Concrete

Precast Vaults

Precast Vaults

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM C857 Standard Practice for Minimum Structural Design Loading for Underground Precast Concrete Utility Structures
- B. ASTM C858 Standard Specification for Underground Precast Concrete Utility Structures

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Type A concrete.
- B. Three maximum number of joints allowed, to consist of base/wall section, middle section, and top/lid section. Wall of base/wall section to be a minimum of 1-foot above crown of pipe.
- C. Joints shall be keyed and butyl rubber type sealant applied, as manufactured by MultiSeal, Inc. or Construction Sealants, Inc. (Conseal).
- D. Factory applied exterior bitumastic waterproofing, minimum dry thickness required 9 – 12 mils.
- E. 12-inch minimum floor thickness with 10-inch deep by 16-inch diameter or 12-inch by 12-inch square sump. Sump shall be located under piping closest to vault ladder with a minimum 4-inch gap between the interior vault wall and the edge of the sump.
- F. Field installed minimum 2-inch thick fill concrete floor with 3,000 PSI concrete. Slope minimum $\frac{1}{4}$ " per foot to the sump with a broom finish.
- G. All vaults shall be installed with top slabs flush to grade.
- H. If vault is provided with preassembled interior piping, a 2-foot pipe stub-out beyond the exterior vault side wall will be required on either side.
- I. Interior vault piping to be painted with 3 coats of Sherwin Williams Macropoxy 646 as follows:
 - Coat 1 – Fairfax Water Green (# 52300049563), 3-4 mils dry film thickness, minimum drying time 8 hours at 77° F
 - Coat 2 – Pillar White (# SW4029), 3-4 mils dry film thickness, minimum drying time 8 hours at 77° F
 - Coat 3 - Fairfax Water Green (# 52300049563), 3-4 mils dry film thickness, minimum drying time 8 hours at 77° F
- J. Field installed Miller DuraHoist wall mount sleeves (Model # DH-8ZP) to accommodate the DuraHoist.

- K. Vaults shall accommodate AASHTO HS 20-44 live load with impact.
- L. Vaults shall be non-buoyant when installed. Manufacturer to provide buoyancy calculations with assumed water table elevation at the ground surface. Calculations shall not include the weights of the piping or equipment installed and shall be sealed by a Professional Engineer licensed in the Commonwealth of Virginia.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Smith-Midland
- B. Oldcastle Precast
- C. Concrete Pipe & Precast, LLC
- D. A.C. Miller Concrete Products, Inc.
- E. Bartow Precast, Inc.

END OF SECTION

Vault Wall Seals

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM C923 Standard Specification for Resilient Connectors Between Reinforced Concrete Manhole Structures, Pipes, and Laterals
- B. ASTM A240 Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
- C. ASTM A666 Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. For Steel or Resilient materials.
- B. Provide corrosion protection when applicable.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. NPC, Inc - Kor-N-Seal

END OF SECTION

DIVISION 5 – METALS

05500 Metal Fabrications

Access Doors

Access Doors

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ASTM B26 Standard Specification for Aluminum-Alloy Sand Castings

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Door shall have gasket and a padlock clasp.
- B. Aluminum castings shall meet the requirements of ASTM B26.
- C. Door leaf shall be 1/4-inch aluminum diamond pattern.
- D. Door shall be reinforced to withstand an HS-20 loading (300 psf) where specified.
- E. Channel Frame shall be 1/4-inch aluminum with a full anchor flange around the perimeter.
- F. Each door leaf shall be equipped as follows:
 - Heavy forged aluminum, stainless steel or brass hinges
 - Automatic hold-open arm with release handle
 - Snap lock with removable handle and recessed hasp covered by a hinged lid flush with surface.
- G. Frame shall have 1 1/2-inch drainage coupling in the front right corner of the channel frame.
- H. Hardware shall be zinc plated and chromate sealed.
- I. Mill finish with bituminous coating applied to exterior of the frame.
- J. Must have recessed locking device.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Bilco Company – Type J, JD, PDCM, J-AL, or JD-AL
- B. Syracuse Castings Sales Corp.
- C. East Jordan Iron Works, Inc.
- D. PA Insert Corporation

END OF SECTION

Vault Ladder Safety Post

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be manufactured of high strength steel or aluminum with telescoping tubular Section that locks automatically when fully extended.
- B. Upward and Downward Movement controlled by a Stainless Steel balancing mechanism.
- C. Finish shall be hot dip galvanized (if constructed of high strength steel).
- D. Unit shall be completely assembled with fasteners for securing to the ladder rungs.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Bilco Company - Model 2 "Ladder Up"
- B. Syracuse Castings Sales Corp.
- C. PA Insert Corporation

END OF SECTION

Vault Ladders

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest and more stringent version of:

- A. 29 CFR 1926.1053 Ladders (OSHA)
- B. 29 CFR 1910.27 Fixed Ladders (OSHA)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be manufactured of 6000-series aluminum with fully-welded construction, including vault connection clips
- B. Loading requirements shall be as stated in 29 CFR 1926.1053(a)(1)(iii).
- C. Rungs shall be square or rectangular with a nonslip top surface.
- D. Ladder shall include continuous side rails from vault floor to top of ladder. Rungs shall be fastened on both ends to side rails.
- E. Clearance between side rails shall be at least 16 inches.
- F. Distance between ladder rungs shall not exceed 12 inches.
- G. Rungs shall not be higher than 12 inches above vault floor or lower than 12 inches below top of vault structure.
- H. Clear distance from vault wall to ladder shall not be less than 7 inches.
- I. Steel washers shall be installed between connection clip and vault wall.
- J. Unit shall be completely fabricated and ready for installation before shipment to the site.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Precision Ladders, LLC Model FLH
- B. PA Insert Corporation

END OF SECTION

DIVISION 13 – SPECIAL CONSTRUCTION

13110 Cathodic Protection

Corrosion Rate Probes

Corrosion Rate Probes

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Probe shall be constructed of molded epoxy.
- B. Sensing element: mild steel, 2.0-inch thick.
- C. Separate ground connection for cable termination.
- D. Cables shall be heavy duty.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Rohrback Cosaco Systems, Inc, - Model 620HD-1-S20-K03005
- B. Cortest Instrument Systems - Model PR11000-S20-620

END OF SECTION

Dielectric Coating – External Pipe Surfaces

Dielectric Coating

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. AWWA C214 Tape Coating Systems for the Exterior of Steel Water Pipelines
- B. AWWA C209 (Shop Applied) Cold-Applied Tape Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Fast drying within two hours.
- B. Cold-applied bitumen, with minimum volume resistivity of 10^{12} ohm-cm.
- C. Only one coating material per entire project.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Royston Laboratories Division (Royston R-28)
- B. Carboline (Bitumastic No. 50)

END OF SECTION

Electric Tape

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Applies to vinyl plastic and rubber splicing.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. 3M Company

END OF SECTION

Insulating Devices
PVC Pipe Inserts

PVC Pipe Inserts

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. AWWA C900 Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings 4-inch through 12-inch for Water Distribution
- B. National Science Foundation Standard 61 Drinking Water System Components

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Plain end piece, minimum three feet long.
- B. Shall be 150 psi (DR 18) pressure class.
- C. Outside diameter same as adjacent pipe.
- D. Shall meet the requirements of AWWA C900.
- E. Shall be NSF 61 approved for use in potable water systems.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Diamond Plastics Corporation
- B. National Pipe and Plastics, Inc. – Dura-Blue
- C. North American Pipe Corporation

END OF SECTION

Insulated Flange

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Insulating Gasket: Shall be NSF 61 certified and constructed of G10 Epoxy Glass with EPDM seals. Inside diameter shall be 3/32-inch less than the net inside diameter of pipe and internal coating or lining.
- B. Insulating Sleeves: G-10 Epoxy/Glass.
- C. Insulating Washers: G-10 Epoxy/Glass. Provide two washers for each bolt.
- D. Steel Washers: 1/8-inch thick plated hot rolled steel. Provide two washers for each bolt.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. PSI Industries, Inc.
- B. Advanced Products & Systems, Inc.

END OF SECTION

Insulated Union

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

Legislation

Product shall comply with:

- A. Public Law 111-380, Reduction of Lead in Drinking Water Act

References

Product shall adhere to the latest version of:

- A. AWWA C800 Underground Service Line Valves and Fittings
- B. NSF 372 Drinking Water System Components – Lead Content (components in contact with potable water)

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Nylon shall be non-brittle and capable of withstanding impacts and loads
- B. An independent laboratory certification must be provided giving evidence that the goods comply with the material standards listed above.
- C. Product must be marked with a lead-free identifier (such as “NL” or “LF”) and with the verifying agency’s mark.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Mueller Co. (Specify “N” after part number when ordering)
- B. Ford Meter Box Company, Inc.

END OF SECTION

Insulated Flange Kit (Isolation Inserts) – Internal Pipe Coating

Insulated Flange Kit

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. National Science Foundation Standard 61 Drinking Water System Components

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Shall be NSF-61 approved for use in potable water systems.
- B. Two component, high or 100% solids epoxy.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. American Chemical Company (Aquatapoxy Coating System A-6)
- B. Dupont Coatings (Corlar 525TL Epoxy Tank Lining)
- C. Advanced Products & Systems, Inc.

END OF SECTION

Petrolatum Tape Coating

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C217 Cold-Applied Petrolatum Tape and Petrolatum Wax tape Coated for the Exterior of Special Sections, Connections, and Fittings for Buried Steel Water Pipe

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Product shall be non-toxic and non-carcinogenic.
- B. Shall be in compliance with AWWA C217.
- C. Compatible primer.
- D. Mastic for profiling around joints, bolts, and other irregular shapes.
- E. Petrolatum impregnated fabric tape that is compatible with other coatings
- F. Outer protective wrap.
- G. All materials shall be from the same manufacturer.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Denso North America Inc.
- B. Trenton Corporation (Wax-Tape)

END OF SECTION

Polyethylene Tubing (Encasement)

Polyethylene Tubing

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product

Summary

References

Product shall adhere to the latest version of:

- A. ANSI/AWWA C105/A21.5 Class B Polyethylene Encasement for Ductile-Iron Pipe Systems

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions

- A. Seamless 4mils. (.1mm) thick high-density cross-laminated polyethylene.
- B. Flat tube form, minimum width based on normal pipe diameter.
- C. 2 ft. (600mm) overlap between sections.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Illinois Tool Works, Inc./Valeron Strength Films
- B. AA Thread Seal Tape, Inc.

END OF SECTION

Polyurethane Coating

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. AWWA C209 (Shop Applied) Cold-Applied Tape Coatings for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines
- B. AWWA C214 Tape Coating Systems for the Exterior of Steel Water Pipelines

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Applies to line pipe, valves, and fittings.
- B. Shop Applied Materials shall be 100-percent polyurethane with the following minimum properties, or approved equal:
 - 1. Adhesion to steel greater than or equal to 2,000 psi
 - 2. Cathodic disbondment less than 15 mm rad.
 - 3. Resistivity 1×10^{14} ohms per cm^2 minimum
 - 4. Dielectric strength greater than 200 volts per mill
 - 5. Final coating shall have minimum dry film thickness of 20 mils.
- C. Field Applied Materials (pipe surfaces not shop coated, other than insulated flange) shall have materials compatible with and approved by shop applied coat manufacturer.
- D. Valves may be painted with two (2) coats of Tnemec Series 140F Pota-Pox Plus, minimum 4.0 mils DFT per coat. Total required paint coating shall be 0.8 mils dry film thickness minimum, applied per manufacturer's recommendations.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Shop Applied:
 - 1. Madison Chemical Industries, Milton, ON, Canada: Corropipe II TX-15
 - 2. Futura Coatings, St. Louis, MO: Protec II
- B. Field Applied:
 - 1. Madison Chemical Industries, Milton, ON, Canada: Corropipe TX-II Touch-up
 - 2. Futura Coatings, St. Louis, MO: Futura-Bond 322 and Futura-Sticks 1755 for small repairs only
 - 3. Royston Laboratories Division, Pittsburgh, PA: Royston One Step Tape (for repairs only)

END OF SECTION

Reference Electrodes

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Permanent copper-copper sulfate reference electrode.
- B. Wire: No. 14 AWG minimum stranded copper, high molecular weight polyethylene or RHH/RHW insulation.
- C. Fifteen years minimum service life.
- D. No greater than +/- 0.01 volt variation.
- E. Packaged backfill to provide a homogenous environment.
- F. Unpackaged electrodes not acceptable.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Borin Manufacturing
- B. Corpro
- C. Electrochemical Devices

END OF SECTION

Steel Hand Stamp

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 3/8-inch letter/numeral height marked as such on the thumb-side.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. C.H. Hanson Company – Model Nos. 22450/22981

END OF SECTION

Survey Markers

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 2-inch, flat, brass, monument.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Sokkia Corporation

END OF SECTION

Test Stations

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Flush Mount: standard Fairfax Water cast iron valve box with custom logo, "FAIRFAX WATER CP TEST" shall be cast into cast iron lid in 1-inch high letters, lid shall be coated with two coats of shop applied OSHA safety blue polyurethane or epoxy paint.
- B. Vaults: cast aluminum test head and cover; terminal block. Double hub with slop fir for 1 ¼-inch pipe, "FAIRFAX WATER" cast into lid, two coats of shop applied OSHA safety blue polyurethane, or epoxy paint, 8-terminal block with on 0.01-ohm shunt and nickel-plated brass or copper bonding strap.
- C. Post Mount: Cast aluminum test head and cover, terminal block. Single hub suitable for thread mounting to 2 ½- inch schedule 40 steel conduit, "FAIRFAX WATER" cast into lid, two coats of shop applied OSHA safety blue polyurethane or epoxy paint. 8-terminal block with one 0.01-ohm shunt and nickel-plated brass or copper bonding strap, 2 ½- inch galvanized steel conduit. Provided by test station manufacture, factory painted same as test head and cover.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Bingham & Taylor – Flush Mount Standard
- B. Gerome Manufacturing Company, Inc. – Vaults, Testox Model 1003
- C. Gerome Manufacturing Company, Inc. – Post Mount, Testox Model 2006
- D. C.P. Kearney Test Services

END OF SECTION

Thermite Welding Equipment

Thermite Welding Equipment

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Mold, weld metal, other material and equipment per manufacturer's recommendations for particular pipe/cable material and size.
- B. Material and equipment shall be from same manufacturer.
- C. Utilize adapter sleeve for all thermite welds.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Erico Products, Inc. – Cadweld
- B. Continental Industries, Inc. - Thermoweld

END OF SECTION

Thermite Weld Coating Materials

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Product shall form a highly resistant electrical insulation seal over a weld site and at the end of a lead wire.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Royston Laboratories Division – Handy Cap with 747 Primer
- B. ThermOweld

END OF SECTION

Utility Warning Tape

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. 3-inch or 6-inch wide, red or yellow tape.
- B. Shall have one or more stainless steel tracer wire laid in sinusoidal wave pattern and laminated between two layers of lead free rot resistant polyethylene.
- C. Tape shall be marked "Caution Cathodic Protection Cable Buried Below" at maximum 36-inch intervals.
- D. Shall have a top layer coating to protect wires and warning message.

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Allen Systems (Detectatape)
- B. Lineguard, Inc. (Lineguard Super Tuff III)

END OF SECTION

Wire Connectors and Terminations

Terminal Lugs

Terminal Lugs

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. One hole non-insulated terminal lug for ¼-inch bolt.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Thomas and Betts Corporation – Series 54100 and Model C10-14
- B. Ideal Industries
- C. Morris Products, Inc.

END OF SECTION

Butt Splices

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Non-insulated style.

PART 2 - PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Thomas and Betts Corporation, Series 5450 and Model 210
- B. Morris Products, Inc.
- C. Burndy, LLC

END OF SECTION

Magnesium Anodes

PART 1 – GENERAL

Section includes: applicable referenced standards and technical requirements of the product.

Summary

References

Product shall adhere to the latest version of:

- A. NONE

System Description

Design and Performance Requirements

Section includes: technical requirements of the product, consisting of, but not limited to material type, dimensions, and conditions.

- A. Materials: Packaged high potential type comprised of magnesium ingot, wire, and prepared backfill.

1. Ingot Weight: 32 pounds.
2. Ingot Nominal Dimensions: Minimum 19 inches long and D-shaped (5 inches by 5 inches).
3. Composition of the anode shall be as follows:

ELEMENT	PERCENT
Aluminum	0.010% Maximum
Manganese	0.50 to 1.30%
Copper	0.02% Maximum
Nickel	0.001% Maximum
Zinc	0.05% Maximum
Iron	0.03% Maximum
Silicon	0.05% Maximum
Other	0.05% each or 0.30% Maximum Total
Magnesium	Remainder

4. Backfill composition by weight:

MATERIAL	PERCENT
Hydrated Gypsum	75%
Bentonite	20%
Sodium Sulfate	5%

5. Wire: AWG No. 12 solid copper wire with TW insulation (black) shall be attached to the anode. Wire to anode attachment shall be by silver solder and sealed to prevent any moisture penetration. Length to meet specific field conditions with no splices other than to common header cable, where indicated.
6. Open Circuit Potential: Magnitude 1.6 volts or greater.
Anode Current: Minimum 0.02 ampere per anode, adjusted to account for number of anodes included in circuit at any given location (e.g. 15 anodes – minimum 0.30 ampere).

PART 2 – PRODUCTS

Manufacturers

Approved Manufacturer(s):

- A. Stuart Steel Protection Corp. – Vibroxed
- B. Piping and Corrosion Specialties
- C. Corrpro

END OF SECTION

This page left intentionally blank.

Fairfax Water

Approved Products List

Manufacturer Index

3

3M Company, 61

A

A.C. Miller Concrete Products, Inc., 54
A.W.R. Grace and Co., 48
A.Y. McDonald Manufacturing Company, 13
AA Thread Seal Tape, Inc., 67
Advanced Products & Systems, Inc., 2, 63, 65
Allen Systems, 75
American AVK, 18
American Cast Iron Pipe Company, 4, 5, 8, 9,
31, 32, 33, 37, 38, 49
American Chemical Company, 65
American Ductile Iron Pipe Company, 51
American Flow Control, 38
APCO Valve & Primer Corporation, 20
Atlantic Gasket Corporation, 32, 33, 51
Atlantic States Cast Iron Pipe Company, 4, 32

B

Backman Foundry, 46
Badger Meter, Inc., 26, 28
Bartow Precast, Inc., 54
Belton, Industries, Inc., 1
BH Runyon Company, 23
Bilco Company, 56, 57
Bingham & Taylor, 22, 29, 30, 72
Borin Manufacturing, 69
Burndy, LLC, 77
BWM, 2

C

C.H. Hanson Company, 70
C.P. Kearney Test Services, 72
Cambridge-Brass, 13
Cambridge-Lee, 42
Carboline, 60
Cascade Waterworks Manufacturing Company,
2
CCI Pipeline Systems, 2
Central Plastics Company, 14
Cerro, 42
Champion Sales & Manufacturing, Inc., 32, 33,
51
Cla-Val Company, 19, 20
Concrete Pipe & Precast, LLC, 54
Clow Valve Company, 18, 36
Clow Water Systems Company, 4, 8, 32, 38

Commercial Pantex Sika, Inc, 3
Contech Construction Products, 3
Continental Industries, Inc., 73
Corpro, 69, 79
Cortest Instrument Systems, 59
Crestwell Trading Company, 22, 30

D

Denso North America Inc., 66
Dezurick, 16
Diamond Plastics Corporation, 62
Dresser, Inc., 34
Dupont Coatings, 65

E

Eagle Foundry/Central Castings Company, 47,
49
East Jordan Iron Works, Inc., 22, 56
EBBA Iron Sales, Inc., 51, 52
Electrochemical Devices, 69
Erico Products, Inc., 73

F

Fast Fabricators, 31
Fastener Technologies, 22, 30
Ford Meter Box Company, Inc., 13, 34, 43, 51,
64
Futura Coatings, 68

G

GA Industries, 15
Gerome Manufacturing Company, Inc., 72
Griffin Pipe Products Company, 4, 32, 33, 49, 51

H

Halstead, 42
Hanson Pipe, 6, 39
Harco, 12
Henry Pratt Company, 16, 17
Hersey Meter, 26
Howell, 42
Hunt Industries, 29

I

Ideal Industries, 76
Illinois Tool Works, Inc., 67
Infact Corporation, 51

Fairfax Water

Approved Products List

Manufacturer Index

J

J&S Valve, 18
JCM Industries, 34, 38, 39, 40, 43
Jinan Kinger Industrial Corporation/Proselect, 49

K

Kennedy Valve Company, 18, 20, 24, 36

L

Lineguard, Inc., 75

M

M&H Valve Company, 18, 36
Madison Chemical Industries, 68
Master Meter, 26
McWane, Inc., 4, 32, 33, 51
Merit Brass, 12
Morris Products, Inc., 76, 77
Mueller Company, 13, 16, 17, 18, 20, 24, 29, 36,
38, 42, 43, 64

N

National Pipe and Plastics, Inc., 62
Neptune Technology Group, 26, 27, 28
North American Pipe Corporation, 62
Northtown Company, 45
Northwest, 5
NPC, Inc., 55

O

Oldcastle Precast, 54

P

PA Insert Corporation, 56, 57, 58
Pacific States Cast Iron Pipe Company, 4, 32
Performance Pipe, 7, 14
Permalok, 5
Philadelphia Gear Corporation, 17
Pipeline Seal and Insulator, Inc., 2
Piping and Corrosion Specialties, 79
PowerSeal Pipeline Products Corp, 2, 34
Precision Ladders, LLC, 58
Pro-Line Safety Products Company, 45
PSI Industries, Inc., 63

R

R.B. Argawalla, 22, 30
RACI, 2
Reading, 42
Republic Steel Corporation, 3
Rohrback Cosaco Systems, Inc, 59
Romac Industries, Inc., 34, 39, 43
Royston Laboratories Division, 60, 68, 74

S

Sensus, 26, 27, 28
Sigma Corporation, 8, 9, 10, 23, 47, 49, 51
SIP Industries, 8, 9, 10
Smith-Blair, Inc., 34, 35, 38, 39, 40, 43, 51
Smith-Midland, 54
Sokkia Corporation, 71
Sonneborn-Lotech, 48
Specification Rubber Products, Inc., 32, 33, 51
Star Pipe Products, 8, 9, 10, 35, 49, 51
Stuart Steel Protection Corp., 48, 79
Syracuse Castings Sales Corp., 56, 57

T

ThermOweld, 74
Thomas and Betts Corporation, 76, 77
Trenton Corporation, 66
Tyler / Union, 8, 9, 10, 38, 47, 49, 51

U

U.S. Pipe and Foundry Company, 4, 8, 9, 10,
18, 31, 32, 33, 36, 37, 38, 47, 49, 51
Uma Foundry, 30

V

Valeron Strength Films, 67
Valmatic, 15, 20, 21

W

Water Key, 23
Waterous, 38
Wieland Copper Products, LLC, 42

Z

Zurn Wilkins, 41

This page left intentionally blank.