



Water Quality Laboratory

Inorganics Analyses

Period of 01/01/2017 TO 12/31/2017

Corbalis Treatment Plant Finished Water

Date Report Generated: 6/08/2017

Parameter	MCL ¹	Units ²	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Quant Limit ³
Aggressive Index Number		Units	11	11	11	11	11	-	-	-	-	-	-	-	N/A
Alkalinity, Bicarbonate		mg/L	60	62	63	64	56	-	-	-	-	-	-	-	0
Alkalinity, Carbonate		mg/L	0	0	0	0	0	-	-	-	-	-	-	-	0
Alkalinity, Hydroxyl		mg/L	0	0	0	0	0	-	-	-	-	-	-	-	0
Alkalinity, Phenolphthalein		mg/L	0	0	0	0	0	-	-	-	-	-	-	-	0
Alkalinity, Total		mg/L	60	62	63	64	56	-	-	-	-	-	-	-	0
Bromate ⁴	10 P	µg/L	BQL	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	5
Bromide		mg/L	0.02	0.04	0.01	0.01	BQL	-	-	-	-	-	-	-	0.01
Carbon Dioxide		mg/L	5	4	6	6	7	-	-	-	-	-	-	-	N/A
Chloride	250 S	mg/L	32.1	21.3	21.4	30.3	21.3	-	-	-	-	-	-	-	5.0
Chlorine, Free ⁴		mg/L	0.2	0.2	0.1	3.3	3.5	-	-	-	-	-	-	-	0.0
Chlorine, Total ⁴		mg/L	3.3	3.4	3.3	3.6	3.6	-	-	-	-	-	-	-	0.0
Color	15 S	Units	0	0	0	0	0	-	-	-	-	-	-	-	0
Dissolved Oxygen		mg/L	14.6	14.1	13.8	11.9	14.6	-	-	-	-	-	-	-	0.0
Fluoride	4.0 P / 2.0 S	mg/L	0.7	0.6	0.8	0.7	0.7	-	-	-	-	-	-	-	0.2
Hardness, Calcium		mg/L	64	85	76	63	56	-	-	-	-	-	-	-	10
Hardness, Total		mg/L	89	102	100	90	76	-	-	-	-	-	-	-	10
Methylene Blue Activated Substances	0.5 S	mg/L	-	-	-	-	-	-	-	-	-	-	-	-	0.05
N, Ammonia (Ammonia as N) ⁴		mg/L	0.83	0.81	0.78	BQL	BQL	-	-	-	-	-	-	-	0.20
N, Nitrate (Nitrate as N)	10 P	mg/L	1.11	1.06	0.99	0.76	0.95	-	-	-	-	-	-	-	0.20
N, Nitrite (Nitrite as N)	1 P	mg/L	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	0.01
pH	6.5 - 8.5 S	Units	7.4	7.5	7.3	7.3	7.2	-	-	-	-	-	-	-	N/A
Phosphate as Phosphorous		mg/L	0.41	0.43	0.43	0.42	0.43	-	-	-	-	-	-	-	0.10
Orthophosphate as PO ₄		mg/L	1.25	1.31	1.32	1.28	1.31	-	-	-	-	-	-	-	0.31
Solids, Total		mg/L	162	184	180	165	150	-	-	-	-	-	-	-	1
Solids, Total Dissolved	500 S	mg/L	-	186	193	145	105	-	-	-	-	-	-	-	1
Solids, Total Suspended		mg/L	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	1
Specific Conductivity		µmhos/cm	287	303	288	281	221	-	-	-	-	-	-	-	0
Sulfate	250 S	mg/L	24.6	42.4	38.5	20.0	15.3	-	-	-	-	-	-	-	5.0
Taste		Units	2	2	2	1	2	-	-	-	-	-	-	-	1
Temperature		°C	10.3	11.4	-	15.7	17.8	-	-	-	-	-	-	-	N/A
Threshold Odor Number	3 S	Units	8	10	6	8	12	-	-	-	-	-	-	-	0
Total Organic Carbon		mg/L	2.0	1.3	1.6	1.5	1.8	-	-	-	-	-	-	-	0.5
Turbidity	≤ 5 P	NTU	0.05	0.05	0.05	0.10	0.05	-	-	-	-	-	-	-	0.05

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter, µmhos/cm = micromhos per centimeter, NTU = Nephelometric Turbidity Units

³Quant Limit = Quantitation Limit : lowest level of measurement, N/A = not applicable

⁴Monthly result composed from an average of parameter results for finished water points of entry to distribution system

- Not sampled

* Analysis pending



Water Quality Laboratory

Metal Analyses

Period of 01/01/2017 TO 12/31/2017

Corbalis Treatment Plant Finished Water

Date Report Generated: 6/08/2017

Parameter	MCL ¹	Units ²	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Quant Limit ³
Aluminum	50 - 200 S	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	25.0
Antimony	6 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Arsenic	10 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Barium	2000 P	µg/L	27.4	-	-	33.1	-	-	-	-	-	-	-	-	25.0
Beryllium	4 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Cadmium	5 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Calcium		mg/L	25.8	-	-	25.9	-	-	-	-	-	-	-	-	1.0
Chromium	100 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Copper	1300 AL	µg/L	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	25.0
Iron	300 S	µg/L	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	25.0
Lead	15 AL	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Magnesium		mg/L	6.6	-	-	7.0	-	-	-	-	-	-	-	-	1.0
Manganese	50 S	µg/L	BQL	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	25.0
Mercury	2 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	0.50
Nickel	100 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Potassium		mg/L	2.6	-	-	2.0	-	-	-	-	-	-	-	-	1.0
Selenium	50 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Silicon		mg/L	2.9	-	-	3.0	-	-	-	-	-	-	-	-	1.0
Silver	100 S	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Sodium		mg/L	17.0	12.8	13.7	17.9	11.7	-	-	-	-	-	-	-	1.0
Thallium	2 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Zinc	5000 S	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	25.0

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter

³Quant Limit = Quantitation Limit : lowest level of measurement

- Not sampled

* Analysis pending