



Water Quality Laboratory

Inorganics Analyses

Period of 01/01/2017 TO 12/31/2017

Distribution Site Representing Corbalis Treatment Plant

Date Report Generated: 5/09/2017

Parameter	MCL ¹	Units ²	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Quant Limit ³
Aggressive Index Number		Units	11	11	11	11	-	-	-	-	-	-	-	-	N/A
Alkalinity, Bicarbonate		mg/L	62	62	63	65	-	-	-	-	-	-	-	-	0
Alkalinity, Carbonate		mg/L	0	0	0	0	-	-	-	-	-	-	-	-	0
Alkalinity, Hydroxyl		mg/L	0	0	0	0	-	-	-	-	-	-	-	-	0
Alkalinity, Phenolphthalein		mg/L	0	0	0	0	-	-	-	-	-	-	-	-	0
Alkalinity, Total		mg/L	62	62	63	65	-	-	-	-	-	-	-	-	0
Bromide		mg/L	0.02	0.03	0.03	0.01	-	-	-	-	-	-	-	-	0.01
Carbon Dioxide		mg/L	5	2	5	3	-	-	-	-	-	-	-	-	N/A
Chloride	250 S	mg/L	31.9	21.1	22.1	30.0	-	-	-	-	-	-	-	-	5.0
Chlorine, Free		mg/L	0.1	0.1	0.1	3.1	-	-	-	-	-	-	-	-	0.0
Chlorine, Total		mg/L	3.2	3.3	2.9	3.4	-	-	-	-	-	-	-	-	0.0
Color	15 S	Units	0	0	0	0	-	-	-	-	-	-	-	-	0
Dissolved Oxygen		mg/L	14.0	15.1	11.4	11.6	-	-	-	-	-	-	-	-	0.0
Fluoride	4.0/2.0 P/S	mg/L	0.7	0.6	0.7	0.7	-	-	-	-	-	-	-	-	0.2
Hardness, Calcium		mg/L	66	82	77	64	-	-	-	-	-	-	-	-	10
Hardness, Total		mg/L	90	101	99	90	-	-	-	-	-	-	-	-	10
Methylene Blue Activated Substances	0.5 S	mg/L	-	-	-	-	-	-	-	-	-	-	-	-	0.05
N, Ammonia (Ammonia as N)		mg/L	0.85	0.82	0.78	BQL	-	-	-	-	-	-	-	-	0.20
N, Nitrate (Nitrate as N)	10 P	mg/L	1.05	1.07	0.95	0.79	-	-	-	-	-	-	-	-	0.20
N, Nitrite (Nitrite as N)	1 P	mg/L	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	-	0.01
pH	6.5 - 8.5 S	Units	7.4	7.7	7.4	7.6	-	-	-	-	-	-	-	-	N/A
Phosphate as Phosphorus		mg/L	0.41	0.41	0.37	0.43	-	-	-	-	-	-	-	-	0.10
Orthophosphate as PO ₄		mg/L	1.26	1.25	1.14	1.31	-	-	-	-	-	-	-	-	0.31
Solids, Total		mg/L	163	173	185	174	-	-	-	-	-	-	-	-	1
Solids, Total Dissolved	500 S	mg/L	-	164	184	142	-	-	-	-	-	-	-	-	1
Solids, Total Suspended		mg/L	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	-	1
Specific Conductivity		µmhos/cm	294	294	292	277	-	-	-	-	-	-	-	-	0
Sulfate	250 S	mg/L	23.7	41.1	37.8	20.0	-	-	-	-	-	-	-	-	5.0
Taste		Units	2	2	2	1	-	-	-	-	-	-	-	-	1
Temperature		°C	8.7	10.6	10.3	15.0	-	-	-	-	-	-	-	-	N/A
Threshold Odor Number	3 S	Units	8	6	7	7	-	-	-	-	-	-	-	-	0
Total Organic Carbon		mg/L	2.0	1.3	1.8	1.6	-	-	-	-	-	-	-	-	0.5
Turbidity	≤ 5 P	NTU	0.05	0.05	0.10	0.15	-	-	-	-	-	-	-	-	0.05

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter, µmhos/cm = micromhos per centimeter, NTU = Nephelometric Turbidity Units

³Quant Limit = Quantitation Limit : lowest level of measurement, N/A = not applicable

- Not sampled

* Analysis pending



Water Quality Laboratory

Metal Analyses

Period of 01/01/2017 TO 12/31/2017

Distribution Site Representing Corbalis Treatment Plant

Date Report Generated: 5/09/2017

Parameter	MCL ¹	Units ²	Jan-17	Feb-17	Mar-17	Apr-17	May-17	Jun-17	Jul-17	Aug-17	Sep-17	Oct-17	Nov-17	Dec-17	Quant Limit ³
Aluminum	50 - 200 S	µg/L	BQL	-	-	*	-	-	-	-	-	-	-	-	25.0
Antimony	6 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Arsenic	10 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Barium	2000 P	µg/L	27.5	-	-	31.9	-	-	-	-	-	-	-	-	25.0
Beryllium	4 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Cadmium	5 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Calcium		mg/L	26.2	-	-	26.4	-	-	-	-	-	-	-	-	1.0
Chromium	100 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Copper	1300 AL	µg/L	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	-	25.0
Iron	300 S	µg/L	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	-	25.0
Lead	15 AL	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Magnesium		mg/L	6.5	-	-	6.9	-	-	-	-	-	-	-	-	1.0
Manganese	50 S	µg/L	BQL	BQL	BQL	BQL	-	-	-	-	-	-	-	-	25.0
Mercury	2 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	0.50
Nickel	100 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Potassium		mg/L	2.6	-	-	2.0	-	-	-	-	-	-	-	-	1.0
Selenium	50 P	µg/L	BQL	-	-	*	-	-	-	-	-	-	-	-	5.0
Silicon		mg/L	2.8	-	-	3.2	-	-	-	-	-	-	-	-	1.0
Silver	100 S	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	5.0
Sodium		mg/L	17.7	12.6	14.1	17.9	-	-	-	-	-	-	-	-	1.0
Thallium	2 P	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	2.0
Zinc	5000 S	µg/L	BQL	-	-	BQL	-	-	-	-	-	-	-	-	25.0

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter

³Quant Limit = Quantitation Limit : lowest level of measurement

- Not sampled

* Analysis pending