



Water Quality Laboratory

Inorganics Analyses

Period of 01/01/2024 TO 12/31/2024

Corbalis Treatment Plant Finished Water

Date Report Generated: 2/16/2024

Parameter	MCL ¹	Units ²	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Quant Limit ³
Aggressive Index Number		Units	11	11	11	11	11	11	11	11	11	11	11	-	N/A
Alkalinity, Bicarbonate		mg/L	80	81	68	83	66	91	88	95	92	90	110	-	0
Alkalinity, Carbonate		mg/L	0	0	0	0	0	0	0	0	0	0	0	-	0
Alkalinity, Hydroxyl		mg/L	0	0	0	0	0	0	0	0	0	0	0	-	0
Alkalinity, Phenolphthalein		mg/L	0	0	0	0	0	0	0	0	0	0	0	-	0
Alkalinity, Total		mg/L	80	81	68	83	66	91	88	95	92	90	110	-	0
Bromate ⁴	10 P	µg/L	*	*	*	*	*	*	*	*	*	*	*	*	5
Bromide		mg/L	BQL	0.01	BQL	BQL	BQL	0.02	0.01	0.01	0.03	0.02	0.03	-	0.01
Carbon Dioxide		mg/L	8	5	5	8	7	9	9	6	9	7	11	-	N/A
Chloride	250 S	mg/L	30.0	22.5	23.9	18.6	25.6	23.7	26.6	38.4	42.2	30.2	31.5	-	5.0
Chlorine, Free ⁴		mg/L	0.1	0.1	0.2	3.3	3.4	3.4	0.4	0.4	0.4	0.1	0.2	-	0.0
Chlorine, Total ⁴		mg/L	3.5	3.7	3.6	3.5	3.6	3.6	3.8	3.9	3.9	3.8	3.7	-	0.0
Color	15 S	Units	0	0	0	0	0	0	0	0	0	0	0	-	0
Dissolved Oxygen		mg/L	13.1	15.5	13.4	14.9	11.6	13.2	13.6	14.6	14.2	13.5	12.7	-	0.0
Fluoride	4.0 P / 2.0 S	mg/L	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	-	0.2
Hardness, Calcium		mg/L	83	90	67	87	64	90	88	92	96	104	126	-	10
Hardness, Total		mg/L	111	121	94	119	89	132	123	139	148	148	181	-	10
Methylene Blue Activated Substances	0.5 S	mg/L	-	-	-	-	-	-	BQL	-	-	-	-	-	0.05
N, Ammonia (Ammonia as N) ⁴		mg/L	0.84	0.83	0.83	BQL	BQL	BQL	0.91	0.88	0.98	0.93	0.89	-	0.20
N, Nitrate (Nitrate as N)	10 P	mg/L	1.60 ⁴	1.46	1.13	0.77 ⁴	0.81	0.36	0.41 ⁴	0.30	0.22	0.38 ⁴	0.47	-	0.20
N, Nitrite (Nitrite as N)	1 P	mg/L	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	-	0.01
pH	6.5 - 8.5 S	Units	7.3	7.5	7.4	7.3	7.3	7.3	7.3	7.5	7.3	7.4	7.3	-	N/A
Phosphate as Phosphorous		mg/L	0.45	0.42	0.45	0.45	0.43	0.39	0.44	0.40	0.43	0.40	0.38	-	0.10
Orthophosphate as PO ₄		mg/L	1.37	1.27	1.37	1.37	1.30	1.19	1.33	1.21	1.32	1.23	1.15	-	0.31
Solids, Total		mg/L	179	193	166	174	131	182	184	240	279	225	263	-	1
Solids, Total Dissolved	500 S	mg/L	176	162	166	150	164	234	190	224	230	240	292	-	1
Solids, Total Suspended		mg/L	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	-	1
Specific Conductivity		µmhos/cm	321	320	269	301	260	342	332	404	443	387	455	-	0
Sulfate	250 S	mg/L	24.3	36.6	20.6	33.2	17.5	40.9	37.0	45.3	58.9	51.5	67.6	-	5.0
Taste		Units	3	2	2	2	2	2	2	2	2	2	2	-	1
Temperature		°C	10.5	10.6	12.2	16.2	18.1	23.0	26.3	27.2	27.2	21.3	18.6	-	N/A
Threshold Odor Number	3 S	Units	12	12	7	6	6	9	7	7	3	3	1	-	0
Total Organic Carbon		mg/L	1.4	1.1	1.6	1.3	1.4	1.4	1.5	1.7	1.5	2.4	1.3	-	0.5
Turbidity	≤ 5 P	NTU	0.15	0.10	0.05	0.05	0.05	0.05	0.15	0.05	0.05	0.05	0.10	-	0.05

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter, µmhos/cm = micromhos per centimeter, NTU = Nephelometric Turbidity Units

³Quant Limit = Quantitation Limit : lowest level of measurement, N/A = not applicable

⁴Monthly result composed from an average of parameter results for finished water points of entry to distribution system

- Not sampled

* Analysis pending



Water Quality Laboratory

Metal Analyses

Period of 01/01/2024 TO 12/31/2024

Corbalis Treatment Plant Finished Water

Date Report Generated: 2/16/2024

Parameter	MCL ¹	Units ²	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23	Quant Limit ³
Aluminum	50 - 200 S	µg/L	BQL	-	-	BQL	-	-	62.7	-	-	34.7	-	-	25.0
Antimony	6 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Arsenic	10 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Barium	2000 P	µg/L	27.7	-	-	40.4	-	-	44.5	-	-	34.1	-	-	25.0
Beryllium	4 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Cadmium	5 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Calcium		mg/L	32.3	-	-	35.6	-	-	34.6	-	-	36.4	-	-	1.0
Chromium	100 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	5.0
Copper	1300 AL	µg/L	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	25.0
Iron	300 S	µg/L	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	25.0
Lead	15 AL	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Magnesium		mg/L	7.1	-	-	8.6	-	-	9.3	-	-	11.0	-	-	1.0
Manganese	50 S	µg/L	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	BQL	25.0
Mercury	2 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	0.50
Nickel	100 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	5.0
Potassium		mg/L	2.2	-	-	2.0	-	-	2.5	-	-	3.4	-	-	1.0
Selenium	50 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	5.0
Silicon		mg/L	4.0	-	-	BQL	-	-	3.8	-	-	1.2	-	-	1.0
Silver	100 S	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	5.0
Sodium		mg/L	15.6	13.0	13.4	11.9	14.3	14.3	15.8	23.0	27.5	19.3	20.6	-	1.0
Thallium	2 P	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	2.0
Zinc	5000 S	µg/L	BQL	-	-	BQL	-	-	BQL	-	-	BQL	-	-	25.0

BQL = The lowest quantitation limit of all analyses for the particular parameter: Below Quantitation Limit

¹Environmental Protection Agency/Virginia Department of Health established levels for drinking water at points of entry to the water distribution system

P = Primary - enforceable, S = Secondary - non-enforceable, AL = Action Level on specific taps, MCL = Maximum Contaminant Level

²mg/L = milligrams per liter, µg/L = micrograms per liter

³Quant Limit = Quantitation Limit : lowest level of measurement

- Not sampled

* Analysis pending