



MORIN BUILDING
8570 EXECUTIVE PARK AVENUE
FAIRFAX, VIRGINIA 22031

Date Issued: October 16, 2018

To: All Prospective Offerors

Issued by: Brian Carter, Buyer I

Subject: Addendum # 1 to IFB # 18-94 Provide 5/8" through 1" Cold Water Meters

The purpose of this addendum is to make revisions to the IFB and to answer questions submitted by the specified deadline for their submission.

I. General

1. The deadline for submitting bids will remain 2:00 p.m, Monday, October 29, 2018.
2. Bids will be opened and read immediately following the submission deadline in Fairfax Water's Procurement Department @ 8570 Executive Park Avenue; Fairfax, VA 22031.

II. Questions and Answers

1. **Q: Request to approve Zenner PMN Multi-Jet and PPD Positive Displacement meters for consideration in this solicitation.**

A: Per IFB section 2.3 Meter Requirements, subsection A.1: Positive displacement meters shall have a nutating disc construction, the above referenced Zenner product uses an oscillating piston. Additionally, Zenner's multi-jet meters have a lower rate of continuous flow than the approved meters listed within the bid document (10-25 gpm vs 15-30 gpm). Fairfax Water will not consider bids for either of the above referenced Zenner meters.

2. **Q: "Will an eight dial visual and encoded output register be accepted if previously supplied to the Authority, as manufactured by Badger Meter, for remote Touch applications?"**

A: Fairfax Water will accept eight-dial registers provided the meter meets all other requirements specified in the bid.

3. **Q: "Will you accept proposal with Ultrasonic water meters?"**

A: Per IFB section 2.2 Reference Standards, subsection A: All displacement meters shall conform to ANSI/AWWA C700-09 for meters with a bronze maincase and IFB section 2.3 Meter Requirements, subsection A.2: Singlejet and Multijet meters shall have a lead-free bronze body. Fairfax Water has determined that Ultrasonic meters use a composite maincase and do not meet the requirements of this solicitation.

**IFB #18-94
Provide 5/8" through 1"
Cold Water Meters**

NO OTHER QUESTIONS WERE RECEIVED BY THE DEADLINE

III. Acknowledgement

Acknowledge your receipt of, and compliance with, this Addendum by either signing the attached acknowledgement, or referencing its receipt and your compliance, in your bid.

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM # 1

I certify that the information contained in the proposal submitted on behalf of the below named firm incorporates any and all changes to the original specification. I further certify by my signature below, that I am fully authorized to acknowledge receipt of the above addendum and also bind the below named firm to the terms, conditions and specifications of the IFB and any changes thereto made by this addendum.

ACKNOWLEDGED BY:

FOR: _____
Company Name

Date

Signature of Authorized Agent

Printed/typed name

Title

