

CONTRACT AMENDMENT #1

This agreement constitutes an Amendment to the Contract to Furnish and Deliver Butterfly Valves between **FAIRFAX WATER** ("FW") and **FREEMIRE AND ASSOCIATES, INC** (the "Contractor") (collectively, the "parties").

In consideration of the mutual covenants set forth herein, the parties agree to amend and modify the Contract effective December 6, 2017 as follows:

Please amend Contract Section 2- Bid Specifications and Related Requirements to read as follows:

2.3 Products

A. Approved Manufacturers and Models:

- 3. DeZURIK – BAW with M, G, or LA-Series Actuator (screw rod on G-Series actuator shall be trimmed so that operating nut is 1-inch from housing).

B. Design and Performance Requirements:


1. General:

- d. Product shall be supplied with certification of compliance with ANSI/AWWA C504, Section 5.1.2 (Leakage Tests), including date tested and test pressure.

In all other respects not specifically mentioned or altered by Amendment, the original Contract shall remain in full force and effect.

FAIRFAX WATER


Procurement Department
 8570 Executive Park Avenue
 Fairfax, VA 22031
 Phone: (703) 289-6261
 Fax: (703) 289-6262

By: 
 Name: Brian Carter
 Title: Buyer I
 Date: 12/14/17

FREEMIRE AND ASSOCIATES, INC

1215 Old Dorsey Rd
 Hermans, MD 21077

Phone: (410) 768-8500
 Fax: (410) 768-3400

By: 
 Name: Mark Wehland
 Title: Vice President
 Date: 12/13/2017