

IFB #16-09
Large Cold Water Meters

Fairfax Water

MORIN BUILDING
8570 EXECUTIVE PARK AVENUE
FAIRFAX, VIRGINIA 22116-0815

Date Issued: July 22, 2016

To: All Prospective Offerors

Issued by: Melanie Tillotson, Buyer II

Subject: Addendum # 1 to IFB # 16-09 Large Cold Water Meters

The purpose of this addendum is to make revisions to the IFB and to answer questions submitted by the specified deadline for their submission.

I. General

1. The deadline for submitting bids has been extended to 2:00 p.m., Tuesday, August 2, 2016
2. Bids will be opened and read immediately following the submission deadline in Fairfax Water's Procurement Department @ 8570 Executive Park Avenue; Fairfax, VA 22031.

II. Questions and Answers

1. Q. Are companion flanges per section 1.5 required on 1 ½" and 2" meters or just the connections spelled out on the bid item list required?
 - A. Companion Flanges will not be required for 1 ½" and 2" Straight Read and Encoder Touch Read Meters.
2. Q. For the 3", 4", and 6" Compound Meters and the 3" and 4" Turbine Meters, can alternative meters such as Ultrasonic Meters be bid for this IFB? If so, will Fairfax Water accept filler pieces to make up the difference in lay lengths between the Compound Meters and the alternative meter?
 - A. First Question – Yes. Second Question – Yes. The touch read registers must meet requirements of the "Sensus Protocol".

NO OTHER QUESTIONS WERE RECEIVED BY THE DEADLINE

III. Acknowledgement

Acknowledge your receipt of, and compliance with, this Addendum by either signing the attached acknowledgement, or referencing its receipt and your compliance, in your bid.

**IFB #16-09
Large Cold Water Meters**

ACKNOWLEDGEMENT OF RECEIPT OF ADDENDUM # 1

I certify that the information contained in the proposal submitted on behalf of the below named firm incorporates any and all changes to the original specification. I further certify by my signature below, that I am fully authorized to acknowledge receipt of the above addendum and also bind the below named firm to the terms, conditions and specifications of the IFB and any changes thereto made by this addendum.

ACKNOWLEDGED BY:

FOR: _____

Company Name

Date

Signature of Authorized Agent

Printed/typed name

Title